

Am Test Inc.
 13600 NE 126TH PL
 Suite C
 Kirkland, WA 98034
 (425) 885-1664
 www.amtestlab.com



**Professional
 Analytical
 Services**


Drinking Water Report for IOC's

Date Collected: 04/25/16	System Group Type: <input type="checkbox"/> A <input type="checkbox"/> B <input checked="" type="checkbox"/> Other: Private
Water System ID Number: PRIVATE	System Name: INGEBRIGHT
Lab--Sample No: 066--06499	County: SNOHOMISH
Sample Location: #2 FAUCET	Source Number(s):
Sample Purpose: (Check Appropriate Box) <input type="checkbox"/> RC - Routine/Compliance (satisfies monitoring requirements) <input type="checkbox"/> C - Confirmation (confirmation of chemical result) <input checked="" type="checkbox"/> I - Investigative (does not satisfy monitoring requirements) <input type="checkbox"/> O - Other (specify)	Date Received: 04/25/16 Date Analyzed: 4/26/16 Nitrates Date Reported: 5/19/16 Comments:
Sample Composition: (Check Appropriate Box) <input checked="" type="checkbox"/> S - Single Source <input type="checkbox"/> B - Blended (List Multiple Source Numbers in Source Nos. field) <input type="checkbox"/> C - Composite (Specify in Comments Field) <input type="checkbox"/> D - Distribution Sample	Sample Type: (Check One) <input checked="" type="checkbox"/> Pre-Treatment/Raw <input type="checkbox"/> Post-Treatment/Finished <input type="checkbox"/> Unknown Sample Collected by: DAVID Phone Number: 425-220-5331
Send Report To: DAVID INGEBRIGHT Attention: DAVID INGEBRIGHT 15819 JORDAN RD ARLINGTON, WA 98223	Bill To: DAVID INGEBRIGHT 15819 JORDAN RD ARLINGTON, WA 98223

EPA Regulated AND STATE REGULATED OR REQUIRED

DOH#	Analytes	Results	Units	SRL	Trigger	MCL	MCL Exceeded? (Check only if YES)	Method/Analyst
4	Arsenic	0.0019	mg/l	0.0014	0.01	0.01		EPA 200.8 /MH
5	Barium	ND	mg/l	0.1	2	2		EPA 200.8 /MH
6	Cadmium	ND	mg/l	0.001	0.005	0.005		EPA 200.8 /MH
7	Chromium	ND	mg/l	0.007	0.1	0.1		EPA 200.8 /MH
11	Mercury	ND	mg/l	0.0002	0.002	0.002		EPA 245.1 /JR
12	Selenium	ND	mg/l	0.002	0.05	0.05		EPA 200.8 /MH
19	Fluoride	ND	mg/l	0.5	4	4		EPA 300.0 /JR
114	Nitrite	ND	mg/l	0.1	0.5	1		EPA 300.0 /JR
20	Nitrate	0.61	mg/l	0.5	5	10		EPA 300.0 /JR
161	Nitrate + Nitrite	0.61	mg/l	0.5	10	10		EPA 300.0 /
13	Silver	ND	mg/l	0.1	--	0.1		EPA 200.8 /MH
14	Sodium	ND	mg/l	5				EPA 200.7 /MH
9	Lead	ND	mg/l	0.001	0.015	0.015		EPA 200.8 /MH

NOTES:
SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH)
Trigger Level: DOH Drinking Water response level. Systems with compounds detected at concentrations in excess of this level are required to take additional samples. Contact your regional DOH office for further information.
MCL (Maximum Contaminant Level): If the contaminant amount exceeds the MCL, immediately contact your regional DOH office.
NA (Not Analyzed): in the results column indicates this compound was no included in the current analysis.
ND (Not Detected): in the results column indicates this compound was analyzed and not detected at a level greater than or equal to the SRL.
<(0.001): indicates the compound was not detected in the sample at or above the concentration indicated.


 Aaron W. Young